

Type of Incident

*(example: Slip-Trip, Fall from Height, Vehicle , Laceration, Chemical Exposure)*

Summary:

A contractor was working on a scaffold, and whilst transitioning from the upper level to the lower level (via a hatch door), the door closed on his hand, resulting in the injured person requiring hospital treatment.

Root Causes:

- No means to secure door, whilst transitioning via levels

Actions Taken Thus Far: Next Steps

- Consult with the scaffold company to make the necessary door modifications.
- Inform all trades using the scaffold of the importance of reporting unsafe equipment.